



2323 Fourth Street
P.O. Box 483
Peru, Illinois 61354
815-224-1650
800-659-4659
FAX 815-224-1688
www.testinc.com

ANALYTICAL REPORT

September 19, 2017

Princeton Grade School
Attn: Mark Gray
506 East Dover Road
Princeton, IL 61356

Order Number: 170900160

TEST, Inc. received 4 samples on August 17, 2017 at 12:00 for the analyses presented in the following report. There were no problems with the analyses and all the data for the associated QC met EPA or laboratory specifications. Exceptions would be described in the Case Narrative, if applicable.

This final Analytical Report consists of this cover letter, case narrative, laboratory results and any accompanying documentation including, but not limited to, chain of custody records.

This report may not be reproduced, except in full, without prior written approval from TEST, Inc.

If you have any questions regarding these test results, please do not hesitate to contact me at (815) 224-1650 or (800) 659-4659.

Sincerely,

Total Environmental Service Technologies, Inc.

A handwritten signature in black ink that reads "Heather Bjork".

Heather Bjork
Quality Assurance Officer



CASE NARRATIVE



CLIENT: Princeton Schools
DATE: September 19, 2017
ORDER NUMBER: 170900160

2323 Fourth Street
P.O. Box 483
Peru, Illinois 61354
815-224-1650
800-659-4659
FAX 815-224-1688
www.testinc.com

GENERAL COMMENTS:

All results reported in wet weight unless otherwise indicated (mg/kg = Dry Weight)

Sample results relate only to the analytes of interest and to sample as received by the laboratory.

Environmental compliance sample results meet the requirements of Part 186 unless otherwise indicated.

Accreditation by the State of Illinois is not an endorsement or a guarantee of the validity of data generated. For more information about the laboratories' scope of accreditation in regards to Alkalinity/SM2320B; TDS/SM2540C; Fluoride/SM4500F-C; pH/SM4500H-B; Nitrite/SM4500NO2-B; Nitrate/EPA 353.2R2.0; Lead/EPA 200.8R5.4, please contact TEST, Inc. or the Agency

LIMIT: Method Detection Limit. The minimum concentration of an analyte that can be measured and reported with a 99% confidence that analyte is greater than zero.

Outside laboratories references under analyst on the Final Report include:

- SB: Suburban Laboratories BE: Bain Environmental ESI: EnviroScience, Inc.
- EML: Environmental Midwest Laboratory UL: Underwriters Laboratories SET: Summit Environmental Technologies, Inc.
- TEK: Teklab, Inc. STA: STAT Analysis Corp. MWH: Eaton Analytical UAS: United Analytical Services

DATA QUALIFIERS:

B: Analyte detected in the associated Method Blank

J: The analyte was positively identified; the associated numerical value is less than the RL but greater than or equal to the MDL, and the concentration is an approximate value

TNTC: Too Numerous to Count

H: Analysis run past method hold time

I: Invalid

T: Sample received outside thermal preservation acceptance criteria

S: Sample sent to subcontracted NELAP Laboratory

Q: Results accepted outside of quality control limits

METHOD REFERENCES:

EPA: USEPA Methods for the Determination of Inorganic Substances in Environmental Samples; Methods for Chemical Analysis of Water and Wastes; Methods for Organic Chemical Analyses of Municipal and Industrial Wastewater; 40CFR136 App A; Methods for Determination of Metals in Environmental Samples; Methods for the Determination of Organic Compounds in Drinking Water

SW: USEPA, Test Methods for Evaluating Solid Waste, SW-846, 3rd Ed, includes Updates I-III

SM: Standard Methods for the Examination of Water and Wastewater, 20th Ed.

D: ASTM, Annual Book of Standards

Reported To:
 Mark Gray
 Princeton Schools
 506 East Dover Road
 Princeton, IL 61356

Order No.: 170900160
P.O. No.: G2966398
Date Received: 08/17/2017
Collected by: Client
Report Date: 09/19/2017

Laboratory Results

Sample No.: 170900160-001 **Location:** Tiskilwa W Drinker 1st Floor
Date Collected: 08/15/2017 **Type:**
Time Collected: 06:00 **Sample Matrix:** Drinking Water

Laboratory Test	Tested Value	Test Units	Detection Limit	Qualifier	Test Method	Date of Analysis	Analyst
Lead, Total/ug	<2	ug/L	2.0		EPA 200.8	9/13/17 15:55	LZ

Sample No.: 170900160-002 **Location:** Tiskilwa W Drinker 1st Floor
Date Collected: 08/15/2017 **Type:**
Time Collected: 06:01 **Sample Matrix:** Drinking Water

Laboratory Test	Tested Value	Test Units	Detection Limit	Qualifier	Test Method	Date of Analysis	Analyst
Lead, Total/ug	<2	ug/L	2.0		EPA 200.8	9/13/17 15:55	LZ

Sample No.: 170900160-003 **Location:** Tiskilwa E Drinker 1st Floor
Date Collected: 08/15/2017 **Type:**
Time Collected: 06:03 **Sample Matrix:** Drinking Water

Laboratory Test	Tested Value	Test Units	Detection Limit	Qualifier	Test Method	Date of Analysis	Analyst
Lead, Total/ug	<2	ug/L	2.0		EPA 200.8	9/13/17 15:55	LZ

Sample No.: 170900160-004 **Location:** Tiskilwa E Drinker 1st Floor
Date Collected: 08/15/2017 **Type:**
Time Collected: 06:04 **Sample Matrix:** Drinking Water

Laboratory Test	Tested Value	Test Units	Detection Limit	Qualifier	Test Method	Date of Analysis	Analyst
Lead, Total/ug	<2	ug/L	2.0		EPA 200.8	9/13/17 15:55	LZ

